

STANDARD FIRE RELATED MESSAGE LIST.

MESSAGE NO:	MESSAGE STATEMENT
200	"MAY WE REMIND YOU THIS IS A NO SMOKING AREA. IF YOU ARE SMOKING KINDLY EXTINGUISH YOUR CIGARETTE IN THE ASHTRAY"
411	BLEEP BLEEP "WARNING, KEEP CLEAR, AUTOMATIC FIRE DOOR CLOSING"
412	BLEEP BLEEP "ATTENTION, FIRE DOOR NOT SHUT"
420	"THIS IS A NO SMOKING AREA, PLEASE EXTINGUISH ALL TOBACCO. THANK YOU" (F)
426	"PLEASE CLOSE THE DOOR, YOU ARE CONTRAVENING THE BUILDING FIRE REGULATIONS" / "PLEASE CLOSE THE DOOR YOU ARE DELAYING THE LIFT"
426/1	"PLEASE CLOSE THE DOOR, YOU ARE CONTRAVENING THE BUILDING FIRE REGULATIONS"
503	"WARNING, WARNING, WILL ALL MEMBERS OF STAFF AND THE PUBLIC PLEASE LEAVE THE PREMISES"
509	"LADIES AND GENTLEMEN, DUE TO UNFORESEEN CIRCUMSTANCES WE MUST ASK YOU TO LEAVE THE PREMISES BY THE MOST AVAILABLE EXIT, OR AS DIRECTED BY STAFF".
518	"ATTENTION, THE FIRE ALARM SYSTEM IS ABOUT TO BE TESTED."
525	FIRE ALARM TEST NOW COMPLETE
526	6 SECOND 2 TONE "YOUR ATTENTION PLEASE, IT IS NECESSARY TO EVACUATE THE BUILDING. PLEASE MAKE YOUR WAY TO THE NEAREST EXIT WHERE STEWARDS WILL DIRECT YOU"
529	ALARM BELL - "THE BUILDING FIRE ALARM SYSTEM HAS OPERATED. DO NOT ENTER THE BUILDING"
531	"IN THE INTEREST OF SAFETY, PLEASE LEAVE THE BUILDING BY THE NEAREST EXIT, STAFF WILL ASSIST YOU"
533	FIRE BELL - "WE HAVE AN EMERGENCY SITUATION. PLEASE LEAVE THE BUILDING BY THE NEAREST EXIT. MEMBERS OF STAFF WILL ASSIST YOU".
534	TWO TONE SOUND "LADIES AND GENTLEMEN, IN THE INTEREST OF SAFETY THIS BUILDING MUST BE EVACUATED. PLEASE LEAVE IMMEDIATELY BY THE NEAREST EXIT, STAFF WILL ASSIST YOU."
545	WARBLE "ATTENTION, THE FIRE DOOR IS NOT SHUT, PLEASE REPORT TO SECURITY RECEPTION"
560	BLEEP, BLEEP, BLEEP, BLEEP "WARNING, TOXIC GAS LEAK, EVACUATE THE AREA"
561	TONE, TONE" CAUTION, FIRE CURTAIN DESCENDING"
562	EMERGENCY CALL POINT HAS BEEN ACTIVATED